

TEST REPORT

Report No :	THSH18102915887-EN		
Applicant	:	Shanghai Yifeng New Materails Co.,Ltd. No.350 Zhuangbei Road, Fengxian District, Shanghai.	
Sample Description	:	PC+ABS Low Smoke and no Halogen Cable Duct	
Model No.	:	L-U/VD/R H/W	
Material No.	:	PC+ABS	
Date Received	:	October 29, 2018	
Test Period	:	October 29, 2018 to October 31, 2018	
Test Requested	:	High temperature test	
Test Method	:	Please refer to next page(s)	
Test Result	:	Please refer to next page(s)	



This document is issued subject to GTS CENERAL CONDITIONS OF SERVICE, and shall not be reproduced except in full or with written approval by GTS Testing. Shanghai Global Testing Services Co., Ltd. Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China. Tel: (86-21) 3363 7866 Fax: (86-21) 3363 7858 E-mail: info@gts-lab.com Web Site: http://www.gts-lab.com

Date: October 31, 2018



TEST REPORT

Report No : THSH18102915887-EN

Date: October 31, 2018

1. Test Equipment:

Equipment Name	Model	Serial No.	Valid Date to
High Temperature Tester	PC-300	TTE20110532	Jan. 15, 2019


2. Environmental Conditions:

Temperature: 24.2°C; Humidity: 51% RH

3. Test Result:

Test Item	Test Condition	Client's Requirement	Test Result
High Temperature Test	90° C, 16 hours	The product has no deformation	Pass

Sample photo(s) before test:



Sample photo(s) during test:



This document is issued subject to GTS CENERAL CONDITIONS OF SERVICE, and shall not be reproduced except in full or with written approval by GTS Testing. Shanghai Global Testing Services Co., Ltd. Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China. Tel: (86-21) 3363 7866 Fax: (86-21) 3363 7858 E-mail: info@gts-lab.com Web Site: http://www.gts-lab.com




TEST REPORT

Report No : THSH18102915887-EN

Date: October 31, 2018

Sample photo(s) after test:



***** End of Report *****